

State of North Carolina
Department of Environment,
Health and Natural Resources
Winston-Salem Regional Office

James B. Hunt, Jr., Governor
Jonathan B. Howes, Secretary
Leesha Fuller, Regional Manager



October 1, 1993

Martin Motor Lines, Inc.
Attn: Paul Martin
3045 Indiana Avenue
Winston-Salem, NC 27105

Subject: Inadequate UST Closure Report for Martin Motor Lines, 3045 Indiana Avenue, Winston-Salem, Forsyth County, North Carolina

Dear Mr. Martin:

Your tank closure report was received on February 16, 1993, but fails to meet our standards for complying with NCAC 2N .0803. Before your report can be accepted, it must include:

1. the location of the product lines, and
2. the location of the dispensers.

Your revised report must be received within 20 days from the letterhead date. I have included 'Guidelines for Assessing Underground Storage Tank Sites...' to help you in completion of the report.

If you have any questions please feel free to contact me at the letterhead address or telephone number.

Sincerely,

Mitch Rose

Mitch Rose
Hydrogeological Technician II

cc: WSRO